 An official website of the United States government  
[Here's how you know](#)



MENU

## Ground Water and Drinking Water

CONTACT US <https://epa.gov/ground-water-and-drinking-water/forms/contact-us-about-ground-water-and-drinking-water>

# National Primary Drinking Water Regulations

### Related Info

- Find out how EPA develops drinking water regulations <https://epa.gov/node/239899>
- Learn about existing EPA drinking water regulations <https://epa.gov/node/115533>
- Read the drinking water section of the Code of Federal Regulations (40 CFR 141) <http://www.gpo.gov>

The National Primary Drinking Water Regulations (NPDWR) (National Primary Drinking Water Regulations) are legally enforceable primary standards and treatment techniques that apply to public water systems. Primary standards and treatment techniques protect public health by limiting the levels of contaminants in drinking water.

- Microorganisms
- Disinfectants
- Disinfection Byproducts
- Inorganic Chemicals
- Organic Chemicals
- Radionuclides

Printable version: Complete NPDWR Table <https://epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulation-table>

### Microorganisms

**Surface Water Treatment Rules** <https://epa.gov/dwreginfo/surface-water-treatment-rules>

**Ground Water Rule** <https://epa.gov/dwreginfo/ground-water-rule>

**Revised Total Coliform Rule And Total Coliform Rule** <https://epa.gov/dwreginfo/revised-total-coliform-rule-and-total-coliform-rule>

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
<i>Cryptosporidium</i>	zero	TT (Treatment Technique) <sup>3</sup>	Gastrointestinal illness (such as diarrhea, vomiting, and cramps)	Human and animal fecal waste
<i>Giardia lamblia</i>	zero	TT (Treatment Technique) <sup>3</sup>	Gastrointestinal illness (such as diarrhea, vomiting, and cramps)	Human and animal fecal waste
Heterotrophic plate count (HPC (Heterotrophic plate count))	n/a	TT (Treatment Technique) <sup>3</sup>	HPC (Heterotrophic plate count) has no health effects; it is an analytic method used to measure the variety of bacteria that are common in water. The lower the concentration of bacteria in drinking water, the better maintained the water system is.	HPC (Heterotrophic plate count) measures a range of bacteria that are naturally present in the environment
<i>Legionella</i> < <a href="https://epa.gov/ground-water-and-drinking-water/legionella">https://epa.gov/ground-water-and-drinking-water/legionella</a> >	zero	TT (Treatment Technique) <sup>3</sup>	Legionnaire's Disease, a type of pneumonia	Found naturally in water; multiplies in heating systems

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
<p>Total Coliforms (including fecal coliform and <i>E. Coli</i>)</p> <ul style="list-style-type: none"> <li>• Quick reference guide</li> <li>• Rule Summary</li> </ul> <p>&lt;<a href="https://epa.gov/dwreginfo/revise...total-coliform-rule-and-total-coliform-rule">https://epa.gov/dwreginfo/revise...total-coliform-rule-and-total-coliform-rule</a>&gt;</p>	zero	5.0% <sup>4</sup>	Not a health threat in itself; it is used to indicate whether other potentially harmful bacteria may be present <sup>5</sup>	Coliforms are naturally present in the environment; as well as feces; fecal coliforms and <i>E. coli</i> only come from human and animal fecal waste.

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Turbidity	n/a	TT (Treatment Technique) <sup>3</sup>	Turbidity is a measure of the cloudiness of water. It is used to indicate water quality and filtration effectiveness (such as whether disease-causing organisms are present). Higher turbidity levels are often associated with higher levels of disease-causing microorganisms such as viruses, parasites and some bacteria. These organisms can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.	Soil runoff
Viruses (enteric)	zero	TT (Treatment Technique) <sup>3</sup>	Gastrointestinal illness (such as diarrhea, vomiting, and cramps)	Human and animal fecal waste

### Disinfection Byproducts

#### Quick reference guide: Stage 1 and 2 Disinfectants and Disinfection Byproducts Rules

**Stage 1 and 2 Rules Summary** <<https://epa.gov/dwreginfo/stage-1-and-stage-2-disinfectants-and-disinfection-byproducts-rules>>

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Bromate	zero	0.010	Increased risk of cancer	Byproduct of drinking water disinfection
Chlorite	0.8	1.0	Anemia; infants and young children: nervous system effects	Byproduct of drinking water disinfection
Haloacetic acids (HAA5) (Haloacetic acids)	n/a <sup>6</sup>	0.060	Increased risk of cancer	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHMs (Total Trihalomethanes))	--> n/a <sup>6</sup>	=====> 0.080	Liver, kidney or central nervous system problems; increased risk of cancer	Byproduct of drinking water disinfection

**Disinfectants**

**Quick reference guide: Stage 1 and 2 Disinfectants and Disinfection Byproducts Rules**

**Stage 1 and 2 Rules Summary** <<https://epa.gov/dwreginfo/stage-1-and-stage-2-disinfectants-and-disinfection-byproducts-rules>>

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
-------------	---	---	---	--

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Chloramines (as Cl <sub>2</sub> (Chlorine)) < <a href="https://epa.gov/dwreginfo/chloramines-drinking-water">https://epa.gov/dwreginfo/chloramines-drinking-water</a> >	MRDLG (Maximum Residual Disinfectant Level Goal)=4 <sup>1</sup>	MRDL (Maximum Residual Disinfectant Level)=4.0 <sup>1</sup>	Eye/nose irritation; stomach discomfort, anemia	Water additive used to control microbes
Chlorine (as Cl <sub>2</sub> (Chlorine))	MRDLG (Maximum Residual Disinfectant Level Goal)=4 <sup>1</sup>	MRDL (Maximum Residual Disinfectant Level)=4.0 <sup>1</sup>	Eye/nose irritation; stomach discomfort	Water additive used to control microbes
Chlorine dioxide (as ClO <sub>2</sub> (Chlorine dioxide))	MRDLG (Maximum Residual Disinfectant Level Goal)=0.8 <sup>1</sup>	MRDL (Maximum Residual Disinfectant Level)=0.8 <sup>1</sup>	Anemia; infants and young children: nervous system effects	Water additive used to control microbes

## Inorganic Chemicals

### Chemical Contaminant Rules Summary <<https://epa.gov/dwreginfo/chemical-contaminant-rules>>

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
-------------	--	---	---	--

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Antimony	0.006	0.006	Increase in blood cholesterol; decrease in blood sugar	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic <ul style="list-style-type: none"> <li>• Quick reference guide</li> <li>• Consumer fact sheet</li> </ul>	0	0.010 as of 01/23/06	Skin damage or problems with circulatory systems, and may have increased risk of getting cancer	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production wastes
Asbestos (fiber > 10 micrometers)	7 million fibers per liter (MFL (Million Fibers per Liter))	7 MFL (Million Fibers per Liter)	Increased risk of developing benign intestinal polyps	Decay of asbestos cement in water mains; erosion of natural deposits

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Barium	2	2	Increase in blood pressure	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium	0.004	0.004	Intestinal lesions	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium	0.005	0.005	Kidney damage	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints



Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Chromium (total) < <a href="https://epa.gov/dwstandardsregulations/chromium-drinking-water">https://epa.gov/dwstandardsregulations/chromium-drinking-water</a> >	0.1	0.1	Allergic dermatitis	Discharge from steel and pulp mills; erosion of natural deposits
Copper	1.3	TT (Treatment Technique) <sup>7</sup> ; Action Level=1.3	Short term exposure: Gastrointestinal distress  Long term exposure: Liver or kidney damage  People with Wilson's Disease should consult their personal doctor if the amount of copper in their water exceeds the action level	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide (as free cyanide)	0.2	0.2	Nerve damage or thyroid problems	Discharge from steel/metal factories; discharge from plastic and fertilizer factories

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Fluoride	4.0	4.0	Bone disease (pain and tenderness of the bones); Children may get mottled teeth	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Lead < <a href="https://epa.gov/node/133825/">https://epa.gov/node/133825/</a> > <ul style="list-style-type: none"> <li>• Quick reference guide</li> <li>• Rule information &lt;<a href="https://epa.gov/node/120819/">https://epa.gov/node/120819/</a>&gt;</li> </ul>	zero	TT (Treatment Technique) <sup>7</sup> ; Action Level=0.015	Infants and children: Delays in physical or mental development; children could show slight deficits in attention span and learning abilities  Adults: Kidney problems; high blood pressure	Corrosion of household plumbing systems; erosion of natural deposits

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long- Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Mercury (inorganic)	0.002	0.002	Kidney damage	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and croplands
Nitrate (measured as Nitrogen)	10	10	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.	Runoff from fertilizer use; leaking from septic tanks, sewage; erosion of natural deposits

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long- Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Nitrite (measured as Nitrogen)	1	1	Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.	Runoff from fertilizer use; leaking from septic tanks, sewage; erosion of natural deposits
Selenium	0.05	0.05	Hair or fingernail loss; numbness in fingers or toes; circulatory problems	Discharge from petroleum refineries; erosion of natural deposits; discharge from mines

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligram per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Thallium	0.0005	0.002	Hair loss; changes in blood; kidney, intestine, or liver problems	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

### Organic Chemicals

#### Chemical Contaminant Rules Summary <<https://epa.gov/dwreginfo/chemical-contaminant-rules>>

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Acrylamide	zero	TT (Treatment Technique) <sup>8</sup>	Nervous system or blood problems; increased risk of cancer	Added to water during sewage/wastewater treatment

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Alachlor	zero	0.002	Eye, liver, kidney or spleen problems; anemia; increased risk of cancer	Runoff from herbicide used on row crops
Atrazine	0.003	0.003	Cardiovascular system or reproductive problems	Runoff from herbicide used on row crops
Benzene	zero	0.005	Anemia; decrease in blood platelets; increased risk of cancer	Discharge from factories; leaching from gas storage tanks and landfills
Benzo(a)pyrene (PAHs)	zero	0.0002	Reproductive difficulties; increased risk of cancer	Leaching from linings of water storage tanks and distribution lines
Carbofuran	0.04	0.04	Problems with blood, nervous system, or reproductive system	Leaching of soil fumigant used on rice and alfalfa
Carbon tetrachloride	zero	0.005	Liver problems; increased risk of cancer	Discharge from chemical plants and other industrial activities

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Chlordane	zero	0.002	Liver or nervous system problems; increased risk of cancer	Residue of banned termiticide
Chlorobenzene	0.1	0.1	Liver or kidney problems	Discharge from chemical and agricultural chemical factories
2,4-D	0.07	0.07	Kidney, liver, or adrenal gland problems	Runoff from herbicide used on row crops
Dalapon	0.2	0.2	Minor kidney changes	Runoff from herbicide used on rights of way
1,2-Dibromo-3-chloropropane (DBCP (1,2-Dibromo-3-chloropropane))	zero	0.0002	Reproductive difficulties; increased risk of cancer	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
o-Dichlorobenzene	0.6	0.6	Liver, kidney, or circulatory system problems	Discharge from industrial chemical factories
p-Dichlorobenzene	0.075	0.075	Anemia; liver, kidney or spleen damage; changes in blood	Discharge from industrial chemical factories

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
1,2-Dichloroethane	zero	0.005	Increased risk of cancer	Discharge from industrial chemical factories
1,1-Dichloroethylene	0.007	0.007	Liver problems	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene	0.07	0.07	Liver problems	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene	0.1	0.1	Liver problems	Discharge from industrial chemical factories
Dichloromethane	zero	0.005	Liver problems; increased risk of cancer	Discharge from drug and chemical factories
1,2-Dichloropropane	zero	0.005	Increased risk of cancer	Discharge from industrial chemical factories
Di(2-ethylhexyl) adipate	0.4	0.4	Weight loss, liver problems, or possible reproductive difficulties.	Discharge from chemical factories
Di(2-ethylhexyl) phthalate	zero	0.006	Reproductive difficulties; liver problems; increased risk of cancer	Discharge from rubber and chemical factories



<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Dinoseb	0.007	0.007	Reproductive difficulties	Runoff from herbicide used on soybeans and vegetables
Dioxin (2,3,7,8-TCDD (Dioxin))	zero	0.00000003	Reproductive difficulties; increased risk of cancer	Emissions from waste incineration and other combustion; discharge from chemical factories
Diquat	0.02	0.02	Cataracts	Runoff from herbicide use
Endothall	0.1	0.1	Stomach and intestinal problems	Runoff from herbicide use
Endrin	0.002	0.002	Liver problems	Residue of banned insecticide
Epichlorohydrin	zero	TT (Treatment Technique) <sup>8</sup>	Increased cancer risk, and over a long period of time, stomach problems	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylbenzene	0.7	0.7	Liver or kidneys problems	Discharge from petroleum refineries

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Ethylene dibromide	zero	0.00005	Problems with liver, stomach, reproductive system, or kidneys; increased risk of cancer	Discharge from petroleum refineries
Glyphosate	0.7	0.7	Kidney problems; reproductive difficulties	Runoff from herbicide use
Heptachlor	zero	0.0004	Liver damage; increased risk of cancer	Residue of banned termiticide
Heptachlor epoxide	zero	0.0002	Liver damage; increased risk of cancer	Breakdown of heptachlor
Hexachlorobenzene	zero	0.001	Liver or kidney problems; reproductive difficulties; increased risk of cancer	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene	0.05	0.05	Kidney or stomach problems	Discharge from chemical factories

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Lindane	0.0002	0.0002	Liver or kidney problems	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor	0.04	0.04	Reproductive difficulties	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl (Vydate)	0.2	0.2	Slight nervous system effects	Runoff/leaching from insecticide used on apples, potatoes, and tomatoes
Polychlorinated biphenyls (PCBs (Polychlorinated biphenyls))	zero	0.0005	Skin changes; thymus gland problems; immune deficiencies; reproductive or nervous system difficulties; increased risk of cancer	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol	zero	0.001	Liver or kidney problems; increased cancer risk	Discharge from wood preserving factories
Picloram	0.5	0.5	Liver problems	Herbicide runoff

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
Simazine	0.004	0.004	Problems with blood	Herbicide runoff
Styrene	0.1	0.1	Liver, kidney, or circulatory system problems	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene	zero	0.005	Liver problems; increased risk of cancer	Discharge from factories and dry cleaners
Toluene	1	1	Nervous system, kidney, or liver problems	Discharge from petroleum factories
Toxaphene	zero	0.003	Kidney, liver, or thyroid problems; increased risk of cancer	Runoff/leaching from insecticide used on cotton and cattle
2,4,5-TP (Silvex)	0.05	0.05	Liver problems	Residue of banned herbicide
1,2,4-Trichlorobenzene	0.07	0.07	Changes in adrenal glands	Discharge from textile finishing factories
1,1,1-Trichloroethane	0.20	0.2	Liver, nervous system, or circulatory problems	Discharge from metal degreasing sites and other factories

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
1,1,2-Trichloroethane	0.003	0.005	Liver, kidney, or immune system problems	Discharge from industrial chemical factories
Trichloroethylene	zero	0.005	Liver problems; increased risk of cancer	Discharge from metal degreasing sites and other factories
Vinyl chloride	zero	0.002	Increased risk of cancer	Leaching from PVC pipes; discharge from plastic factories
Xylenes (total)	10	10	Nervous system damage	Discharge from petroleum factories; discharge from chemical factories

## Radionuclides

### Quick Reference Guide

**Radionuclides Rule Information and Summary** <<https://epa.gov/dwreginfo/radionuclides-rule>>

<b>Contaminant</b>	<b>MCLG (Maximum Contaminant Level Goal)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>MCL (Maximum Contaminant Level) or TT (Treatment Technique)<sup>1</sup> (mg/L (Milligrams per Liter))<sup>2</sup></b>	<b>Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)</b>	<b>Sources of Contaminant in Drinking Water</b>
--------------------	--	--	--	---

Contaminant	MCLG (Maximum Contaminant Level Goal) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	MCL (Maximum Contaminant Level) or TT (Treatment Technique) <sup>1</sup> (mg/L (Milligrams per Liter)) <sup>2</sup>	Potential Health Effects from Long-Term Exposure Above the MCL (Maximum Contaminant Level) (unless specified as short-term)	Sources of Contaminant in Drinking Water
Alpha particles	none ----- zero	15 picocuries per Liter (pCi/L (Picocuries per Liter))	Increased risk of cancer	Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation
Beta particles and photon emitters	none ----- zero	4 millirems per year	Increased risk of cancer	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation
Radium 226 and Radium 228 (combined)	none ----- zero	5 pCi/L (Picocuries per Liter)	Increased risk of cancer	Erosion of natural deposits
Uranium	zero	30 ug/L (microgram per liter) as of 12/08/03	Increased risk of cancer, kidney toxicity	Erosion of natural deposits

## Notes

<sup>1</sup>Definitions:

- Maximum Contaminant Level Goal (MCLG (Maximum Contaminant Level Goal)) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety and are non-enforceable public health goals.
- Maximum Contaminant Level (MCL (Maximum Contaminant Level)) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology and taking cost into consideration. MCLs are enforceable standards.

- Maximum Residual Disinfectant Level Goal (MRDLG (Maximum Residual Disinfectant Level Goal)) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs (Maximum Residual Disinfectant Level Goal) do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT (Treatment Technique)) - A required process intended to reduce the level of a contaminant in drinking water.
- Maximum Residual Disinfectant Level (MRDL (Maximum Residual Disinfectant Level)) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

<sup>2</sup> Units are in milligrams per liter (mg/L (Milligrams per Liter)) unless otherwise noted. Milligrams per liter are equivalent to parts per million (PPM (Parts per Million)).

<sup>3</sup> EPA's surface water treatment rules require systems using surface water or ground water under the direct influence of surface water to

- Disinfect their water, and
- Filter their water, or
- Meet criteria for avoiding filtration so that the following contaminants are controlled at the following levels:
  - *Cryptosporidium*: Unfiltered systems are required to include *Cryptosporidium* in their existing watershed control provisions
  - *Giardia lamblia*: 99.9% removal/inactivation.
  - Viruses: 99.99% removal/inactivation.
  - *Legionella*: No limit, but EPA believes that if *Giardia* and viruses are removed/inactivated, according to the treatment techniques in the Surface Water Treatment Rule, *Legionella* will also be controlled.
  - Turbidity: For systems that use conventional or direct filtration, at no time can turbidity (cloudiness of water) go higher than 1 Nephelometric Turbidity Unit (NTU) (Nephelometric Turbidity Unit), and samples for turbidity must be less than or equal to 0.3 NTUs (Nephelometric Turbidity Units) in at least 95 percent of the samples in any month. Systems that use filtration other than the conventional or direct filtration must follow state limits, which must include turbidity at no time exceeding 5 NTUs (Nephelometric Turbidity Units).
  - Heterotrophic Plate Count (HPC) (Heterotrophic Plate Count): No more than 500 bacterial colonies per milliliter.
  - Long Term 1 Enhanced Surface Water Treatment: Surface water systems or groundwater under the direct influence (GWUDI (Groundwater Under The Direct Influence)) systems serving fewer than 10,000 people must comply with the applicable Long Term 1 Enhanced Surface Water Treatment Rule provisions (such as turbidity standards, individual filter monitoring, *Cryptosporidium* removal requirements, updated watershed control requirements for unfiltered systems).
  - Long Term 2 Enhanced Surface Water Treatment Rule: This rule applies to all surface water systems or ground water systems under the direct influence of surface water. The rule targets additional *Cryptosporidium* treatment requirements for higher risk systems and includes provisions to reduce risks from uncovered finished water storage facilities and to ensure that the systems maintain microbial protection as they take steps to reduce the formation of disinfection byproducts.
  - Filter Backwash Recycling: This rule requires systems that recycle to return specific recycle flows through all processes of the system's existing conventional or direct filtration system or at an alternate location approved by the state.

<sup>4</sup> No more than 5.0% samples total coliform-positive (TC-positive (Total Coliform-positive)) in a month. (For water systems that collect fewer than 40 routine samples per month, no more than one sample can be total coliform-positive per month.) Every sample that has total coliform must be analyzed for either fecal coliforms or *E. coli* if two consecutive TC-positive (Total Coliform-positive) samples, and one is also positive for *E. coli* fecal coliforms, system has an acute MCL (Maximum Contaminant Level) violation.

<sup>5</sup> Fecal coliform and *E. coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Disease-causing microbes (pathogens) in these wastes can cause diarrhea, cramps, nausea, headaches, or other symptoms. These pathogens may pose a special health risk for infants, young children, and people with severely compromised immune systems.

<sup>6</sup> Although there is no collective MCLG (Maximum Contaminant Level Goal) for this contaminant group, there are individual MCLGs (Maximum Contaminant Level Goals) for some of the individual contaminants:

- Trihalomethanes: bromodichloromethane (zero); bromoform (zero); dibromochloromethane (0.06 mg/L (Milligrams per Liter)); chloroform (0.07 mg/L (Milligrams per Liter)).
- Haloacetic acids: dichloroacetic acid (zero); trichloroacetic acid (0.02 mg/L (Milligrams per Liter)); monochloroacetic acid (0.07mg/L (Milligrams per Liter)). Bromoacetic acid and dibromoacetic acid are regulated with this group but have no MCLGs.

<sup>7</sup> Lead and copper are regulated by a treatment technique that requires systems to control the corrosiveness of their water. If more than 10% of tap water samples exceed the action level, water systems must take additional steps. For copper, the action level is 1.3 mg/L (Milligrams per Liter), and for lead is 0.015 mg/L (Milligrams per Liter).

<sup>8</sup> Each water system must certify, in writing, to the state (using third-party or manufacturer's certification) that when acrylamide and epichlorohydrin are used to treat water, the combination (or product) of dose and monomer level does not exceed the levels specified, as follows:

- Acrylamide = 0.05% dosed at 1 mg/L (Milligrams per Liter) (or equivalent)
- Epichlorohydrin = 0.01% dosed at 20 mg/L (Milligrams per Liter) (or equivalent)

---

[Ground Water and Drinking Water Home <https://www.epa.gov/ground-water-and-drinking-water>](https://www.epa.gov/ground-water-and-drinking-water)

---

[Basic Information <https://www.epa.gov/ground-water-and-drinking-water/drinking-water-your-home>](https://www.epa.gov/ground-water-and-drinking-water/drinking-water-your-home)

---

[Private Wells <https://www.epa.gov/privatewells>](https://www.epa.gov/privatewells)

---

[Consumer Confidence Reports <https://www.epa.gov/ccr>](https://www.epa.gov/ccr)

---

[Regulatory Requirements <https://www.epa.gov/dwreginfo>](https://www.epa.gov/dwreginfo)

---

[Standards and Regulations <https://epa.gov/sdwa>](https://epa.gov/sdwa)

---

[All Drinking Water Topics <https://epa.gov/ground-water-and-drinking-water/drinking-water-topics>](https://epa.gov/ground-water-and-drinking-water/drinking-water-topics)

---

[Safe Drinking Water Information System](#)

---

[For Students and Teachers <https://www.epa.gov/ground-water-and-drinking-water/drinking-water-activities-kids-and-teachers>](https://www.epa.gov/ground-water-and-drinking-water/drinking-water-activities-kids-and-teachers)

---



Contact Us <<https://epa.gov/ground-water-and-drinking-water/forms/contact-us-about-ground-water-and-drinking-water>> to ask a question, provide feedback, or report a problem.

LAST UPDATED ON JANUARY 26, 2022



## Discover.

**Accessibility Statement** <<https://epa.gov/accessibility/epa-accessibility-statement>>

**Budget & Performance** <<https://epa.gov/planandbudget>>

**Contracting** <<https://epa.gov/contracts>>

**EPA www Web Snapshot** <<https://epa.gov/utilities/wwwepagov-snapshots>>

**Grants** <<https://epa.gov/grants>>

**No FEAR Act Data** <<https://epa.gov/ocr/whistleblower-protections-epa-and-how-they-relate-non-disclosure-agreements-signed-epa>>

**Plain Writing** <<https://epa.gov/web-policies-and-procedures/plain-writing>>

**Privacy** <<https://epa.gov/privacy>>

**Privacy and Security Notice** <<https://epa.gov/privacy/privacy-and-security-notice>>

## Connect.


**Data.gov**  <<https://www.data.gov/>>

**Inspector General** <<https://epa.gov/office-inspector-general/about-epas-office-inspector-general>>

**Jobs** <<https://epa.gov/careers>>

**Newsroom** <<https://epa.gov/newsroom>>

**Open Government** <<https://epa.gov/data>>

**Regulations.gov**  <<https://www.regulations.gov/>>

**Subscribe** <<https://epa.gov/newsroom/email-subscriptions-epa-news-releases>>

**USA.gov**  <<https://www.usa.gov/>>

**White House**  <<https://www.whitehouse.gov/>>

## Ask.

**Contact EPA** <<https://epa.gov/home/forms/contact-epa>>

**EPA Disclaimers** <<https://epa.gov/web-policies-and-procedures/epa-disclaimers>>

**Hotlines** <<https://epa.gov/aboutepa/epa-hotlines>>

**FOIA Requests** <<https://epa.gov/foia>>

**Frequent Questions** <<https://epa.gov/home/frequent-questions-specific-epa-programtopics>>

## Follow.



