



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

January 25, 2017

ADRIENNE BRINK
AJ BRINKS AT SWEETWATER RESORT - PWSID CO0223727
3406 SWEETWATER LAKE ROAD
GYPSUM, CO 81637

Reclassification to Non-Public Water System

Dear ADRIENNE BRINK:

On December 1, 2016, the Colorado Department of Public Health and Environment ("Department") notified AJ BRINKS AT SWEETWATER RESORT ("Supplier") that the Supplier's water system met the definition of a Transient, Non-Community (TNC) public water system based upon the Department's October 2, 2016 site visit, pursuant to the Colorado Primary Drinking Water Regulations ("Regulation 11"), 5 CCR 1002-11. On December 23, 2016, the Supplier submitted data from its reservation calendar. Based on the Supplier's data, the Supplier serves an average of 23 people during the Supplier's busiest 60 days. Therefore, the Supplier does not meet the definition of a Public Water System as stated in the Colorado Primary Drinking Water Regulations ("Regulation 11"), 5 CCR 1002-11.

Therefore, the Supplier is now classified as Non-Public since it has less than fifteen (15) service connections, and does not regularly serve an average of at least 25 individuals daily at least 60 days per year. **Please note that the Department must be notified if at any time the Supplier has at least fifteen (15) service connections or regularly serves an average of at least 25 individuals daily at least 60 days per year.** The Department will follow up with the Supplier annually for population updates.

Please be advised, if the Supplier is supplying water to the public as part of its operation (such as a restaurant, child care, or school) alternate regulations for water may apply. For more information on regulations pertaining to those operations please visit colorado.gov/cdphe or contact your local health department.

If there are any questions regarding the contents of this letter and/or requirements for the Supplier, please contact Nicole Graziano by phone at 303.692.3258 or by email at nicole.graziano@state.co.us.

ec:

ADRIENNE BRINK - AC
YVONNE LONG - PUBLIC HEALTH DIRECTOR - GARFIELD COUNTY PUBLIC HEALTH AGENCY
MORGAN HILL - ENVIRONMENTAL PROTECTION SPECIALIST SAFE DRINKING WATER - GARFIELD COUNTY PUBLIC HEALTH AGENCY

File: CO0223727, GARFIELD COUNTY, TRANSIENT, NON-COMMUNITY - GROUNDWATER

